

Electrical & Power Control Interfaces

AOFS defines the electrical and power control architecture to **safely operate pumps, valves, and irrigation loads** under any power source. It is designed to **ensure fail-safe operation, energy efficiency, and compliance with AOFS standards**, independent of whether the farm uses grid, generator, or solar power.

1. Core Power Principles

- AOFS is **power-source agnostic**: it works with grid, generator, solar, or hybrid systems.
- Controllers must enforce **fail-safe operation** for irrigation and actuation regardless of the power source.
- Systems must support **safe shutdowns** in case of power anomalies or failures.
- AOFS may track **energy consumption of pumps and actuators** to support optional logging, reporting, and operator awareness. **Recommended for off-grid or weak-grid farms, but not required** for farms with stable grid power.

2. Optional Solar Integration

AOFS supports optional solar monitoring for farms that want to optimize energy usage:

- **Level 1 - Minimal Monitoring (Recommended for off-grid / weak-grid farms)**
 - Field Controllers may monitor battery voltage and current.
 - Supports reliable irrigation operation when solar/battery power is used.
 - Fully optional for farms with stable grid or generator power.
- **Level 2 - Integrated Monitoring (Optional Advanced Module)**
 - Controllers can read solar generation metrics from panels/inverters via standard protocols (e.g., Modbus, MQTT, RS485).
 - Enables dynamic irrigation scheduling based on energy availability.
 - Supports advanced PUE analytics and reporting.
 - Completely optional — AOFS compliance does **not depend** on it.

3. Optional Energy-Aware Operation

- AOFS controllers **may** measure power consumption of pumps, valves, and other actuators while running.
- Controllers **may** estimate battery drain or energy availability for upcoming scheduled irrigation events.
- AOFS supports **event prioritization**:
 - Each scheduled irrigation or actuator event can be assigned an **urgency or importance level** by operators.
 - If insufficient energy is available:
 - Low-priority events can be **delayed or skipped**.
 - High-priority events are executed **as soon as sufficient energy is available**.

- Optional alerts notify operators of skipped or delayed events.
- AOFS can provide **proactive scheduling guidance** (optional):
 - When the operator attempts to schedule an irrigation or actuator event, the system **may simulate expected energy usage and availability**.
 - The controller can then **warn the operator**: "Based on current energy estimates, you will most likely not have enough power for this event."
 - Operators may then adjust **priority, timing, or load** before committing the schedule.
- All energy measurements, prioritization decisions, and resulting operational logs **may be recorded** for later analysis:
 - Enables visualization of energy usage and event execution history.
 - Helps operators determine if additional batteries, solar panels, or load rescheduling are needed.

4. Implementation Guidelines

- AOFS compliance does **not require any specific power source, monitoring, or energy-aware operation**.
- Optional monitoring modules should follow AOFS **data logging and offline-first principles**.
- All controllers and modules, regardless of power source, **must enforce local fail-safes** for pumps, valves, and critical irrigation operations.

From:

<http://wiki.irrigation.afriticgroup.com/> - **Afritic Open Farming Standard**

Permanent link:

<http://wiki.irrigation.afriticgroup.com/doku.php?id=electrical:start&rev=1769035730>

Last update: **2026/01/21 22:48**

